

**LGAI**

LGAI Technological Center, S.A.  
Campus UAB s/n  
Apartado de Correos 18  
E - 08193 Bellaterra (Barcelona)  
T +34 93 567 20 00  
F +34 93 567 20 01  
www.appluslaboratories.com



Bellaterra, 9<sup>th</sup> October, 2019

LGAI Technological Center, S.A informs that carried out the following tests for AWP cabinet range models with CMP motors.

**Test Standard:** EN 12101-3:2015

| <b>Model</b>     | <b>File N°</b> | <b>Test date</b> | <b>Power</b> | <b>Tension/frequency</b> |
|------------------|----------------|------------------|--------------|--------------------------|
| AWP 550 cabinet  | 19/19576-1698  | 01/10/19         | 5,5 kW       | 400V/50 Hz               |
| AWP 750 cabinet  | 19/19576-1700  | 02/10/19         | 11 kW        | 400V/50 Hz               |
| AWP 1100 cabinet | 19/19576-1701  | 03/10/19         | 22 kW        | 400V/50 Hz               |

**Classification according to EN 13501-4:**

**F<sub>300</sub> 60**

The fans were tested during 120 minutes without causing any failure.

Sincerely

David Espinosa Amoretti  
Fire resistance technician

---

This document is merely for informational purposes.

The results concern solely and exclusively with the tested samples at the moment and the indicated conditions.

The valid documents are the respective test and range reports completed and emitted by Applus- LGAI.

The results specified here are provisional and subject to possible changes to official test report.