

Declaration of Conformity for Smoke-Spill Motors

We CMP ELECTRIC MOTOR (AUSTRALIA) PTY LTD

Of 12 Treetops Avenue South Penrith
2750 Sydney N.S.W

Declare that the product

Product Name Induction Motor

Model DBA Series

Frame Size 71-355

Insulation Class H

To which this declaration relates is in conformance with the following standard:

Title

Method of test and rating requirements for smoke spill fans


Rating 250°C for 120 minutes

Date of issue 2019

Application Dual Purpose

This declaration is supported by independent Test Standard: GB/T1032-2012
carried out by CNAS L1145.

Signed by
Title
Date



John Edward
Managing Director
October 10, 2019